

Protocol of the intercomparison at Reading, U.K. from June 15 to 19, 2026 with the travelling reference spectroradiometer QASUME from PMOD/WRC

Report prepared by Julian Gröbner

Operator: Julian Gröbner

The purpose of the visit was the comparison of global solar irradiance measurements between the Bentham DM150 spectroradiometer operated at the University of Reading by the Univ. of Manchester and the travel reference spectroradiometer QASUME. The measurement site is located at the University of Reading; Latitude 51.441 N, Longitude 0.937 W and altitude 50 m.a.s.l. The horizon of the measurement site is free down to at least 85° solar zenith angle (SZA). Measurements between 6:00 UT and 18:00 UT have been analysed.

QASUME was installed in the morning of June 15, 2026. The spectroradiometer was installed within 1 m of the entrance optic of the local spectroradiometer. The intercomparison between QASUME and the local spectroradiometer lasted five days, from the morning of June 15 to noon of June 19.

QASUME was calibrated several times during the intercomparison period using a portable calibration system. Three lamps (T157824, T157825, T68523) were used to obtain an absolute spectral irradiance calibration traceable to the primary reference held at PMOD/WRC, which is traceable to PTB. The daily mean responsivity of the instrument based on these calibrations varied by less than 1 % during the intercomparison period. The internal temperature of QASUME was 27.37 ± 0.07 °C and the diffuser head was heated to a temperature of 29.11 ± 0.45 °C.

The wavelength shifts relative to an extraterrestrial spectrum as retrieved from the matSHIC analysis were between ± 50 pm in the spectral range 290 to 500 nm.

Protocol:

The measurement protocol was to measure one solar irradiance spectrum every 30 minutes from 290 to 500 nm, every 0.5 nm, and 3.0 seconds between each wavelength increment. QASUME recorded the spectra in 30 min intervals with 0.25 nm increments.

DOY	Date	Day	Weather	Comments (times in UT)
166	15 June	Monday	Mix of sun and clouds.	7:50 QASUME installed. 12:50 T157825. 13:10 T157824.
167	16 June	Tuesday	Mix of sun and clouds	9:50 T157825
168	17 June	Wednesday	Mix of sun and clouds	11:15 T157825
169	18 June	Thursday	Mostly overcast. Clears up in the afternoon.	
170	19 June	Friday	Clear sky in the morning	9:50 T157825 10:10 T68523 11:00 QASUME OFF

Results:

In total 112 synchronised simultaneous spectra from QASUME and the local spectroradiometer D26 are available from the measurement period. Measurements between 4:30 UT and 19:30 UT have been analysed (SZA smaller than 85°). Many ratios between D26 and QASUME are noisy due to fast moving clouds. The submitted spectra from D26 were not corrected for wavelengths shifts by the operator. A revised dataset was submitted by the local operator after the campaign.

Remarks:

1. The Spectroradiometer D26 was very stable during the whole measurement period with a ratio to QASUME very close to 1 at wavelengths longer than 360 nm. At shorter wavelengths, D26 underestimates solar irradiance by about 2% to 3%.
2. A constant wavelengths shift of D26 of about 0.4 nm was observed. It is nearly uniform across the whole spectrum. While the solar irradiance spectra are corrected for this wavelength shift, it will affect the calibration of D26.
3. Some angular response related effect of about 5% was observed in the afternoon of June 18 when the sky was clear. This could be due to an angular response error, or a levelling error of the entrance optic.
4. The long-term stability of D26 (Figure 1), based on the 5 site visits performed so far (2003, 2012, 2018, 2022, and 2026), is approximately 10%, with ratios to QASUME varying from 0.92 in 2012 and 2026 to 1.02 in 2018. If the average measurement from the visit of 2012 is excluded, all measurements are within $\pm 4\%$ of QASUME.

Summary:

Assuming an expanded relative uncertainty of D26 of 5%, the measurements of D26 are within the combined uncertainties for wavelengths longer than 360 nm, but outside at shorter wavelengths.

Recommendations:

1. The traceability chain from primary standard (1 kW FEL lamp) to secondary standards used for on-site calibrations should be verified.
2. The wavelength shift of 0.4 nm has an impact on the calibration of D26 and should be corrected.
3. The levelling of the entrance optic should be verified.




Figure 1 Average ratios between D26 and QASUME from this and previous site visits.


Local Operator: Richard Kift, Omer Celebi


Comments from the operator:



The initial dataset on the first day was based on a correction using the 200 W lamp ratio as we usually only alter the calibration file if there is a change $> 2\%$ to the ratio so I made a small change to the calibration file to correct the ratio to ~ 1 .



As regards the revised data, I found that the larger than expected wavelength shift caused an error in our 200 W check as we use unshicced files. Correcting for this improved the dataset.



UV Index Reading, June 2026































UVRES/SSDS for b5503





IMG 121